

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:
6/8/2015 **2014**

Influent Flow and Loading

1. Monthly Average Flows and (C)BOD Loadings

1.1 Verify the following monthly flows and (C)BOD loadings to your facility.

Outfall No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average (C)BOD Concentration mg/L	x	8.34	=	Influent Monthly Average (C)BOD Loading, lbs/day
January	0.0614	x	161	x	8.34	=	82
February	0.0557	x	157	x	8.34	=	73
March	0.0802	x	80	x	8.34	=	53
April	0.0711	x	66	x	8.34	=	39
May	0.0687	x	68	x	8.34	=	39
June	0.0672	x	70	x	8.34	=	39
July	0.0592	x	52	x	8.34	=	26
August	0.0584	x	190	x	8.34	=	93
September	0.0598	x	31	x	8.34	=	16
October	0.0540	x	33	x	8.34	=	15
November	0.0498	x	130	x	8.34	=	54
December	0.0526	x	161	x	8.34	=	82

2. Maximum Month Design Flow and Design (C)BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	.15	x	90	=	0.135
		x	100	=	.15
Design (C)BOD, lbs/day	255	x	90	=	229.5
		x	100	=	255

2.2 Verify the number of times the flow and (C)BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times (C)BOD was greater than 90% of design	Number of times (C)BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
Total Number of Points					0

0

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:

6/8/2015

2014

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?

☒ Yes

Enter last calibration date (MM/DD/YYYY) 10/15/2014

☐ No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

☒ Yes

☐ No

If No, please explain:

WE revised our ordinance in 2014 and now include discharge limits for BOD, SS, Phos., Ammonia Chlorides and zinc.

4.2 Was it necessary to enforce the ordinance?

☐ Yes

☒ No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks

Holding Tanks

Grease Traps

☐ Yes

☐ Yes

☐ Yes

☒ No

☒ No

☒ No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

☐ Yes

gallons

☒ No

Holding Tanks

☐ Yes

gallons

☒ No

Grease Traps

☐ Yes

gallons

☒ No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

☒ Yes

☐ No

If yes, describe the situation and your community's response.

WE are having problems with excessive Chloride discharges into our system and are therefore unable to many months meet our effluent limit for Chlorides

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:

6/8/2015

2014

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

☐ Yes

☒ No

If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.

--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:
6/8/2015 **2014**

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	20	18	7	1	0	0
February	20	18	8	1	0	0
March	20	18	5	1	0	0
April	20	18	7	1	0	0
May	20	18	7	1	0	0
June	20	18	6	1	0	0
July	20	18	5	1	0	0
August	20	18	6	1	0	0
September	20	18	5	1	0	0
October	20	18	10	1	0	0
November	20	18	10	1	0	0
December	20	18	8	1	0	0

* Equals limit if limit is ≤ 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
Total number of points			0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

☒ Yes

Enter last calibration date (MM/DD/YYYY)

10/15/2014

☐ No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

Freezing weather caused problems with the operation of the clarifier.

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

☒ Yes

☐ No

If Yes, please explain:

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:
6/8/2015 **2014**

We exceeded our Chloride limits. We monitored the entire system looking for the source of the chlorides and we also monitored for excessive zinc discharges.

4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?

☐ Yes

☒ No

If Yes, please explain:

4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?

☐ Yes

☐ No

☒ N/A

Please explain unless not applicable:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:
6/8/2015 **2014**

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	20	18	7	1	0	0
February	20	18	9	1	0	0
March	20	18	6	1	0	0
April	20	18	9	1	0	0
May	20	18	5	1	0	0
June	20	18	7	1	0	0
July	20	18	7	1	0	0
August	20	18	4	1	0	0
September	20	18	6	1	0	0
October	20	18	6	1	0	0
November	20	18	9	1	0	0
December	20	18	9	1	0	0

* Equals limit if limit is <= 10

Months of Discharge/yr	12		
Points per each exceedance with 12 months of discharge:		7	3
Exceedances		0	0
Points		0	0
Total Number of Points			0

0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

No action required

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:
6/8/2015 **2014**

Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for NH3

Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceed ance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceed ance
January	12.4		3.274444444	0					
February	12.4		5.9875	0					
March	12.4		2.681111111	0					
April	12.4		.434444444	0					
May									
June									
July									
August									
September									
October									
November	12.4		.6645	0					
December	12.4		.933	0					
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									0
Points:									0
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
Total Number of Points									0

0

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to detect exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to detect exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

no action required

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:
6/8/2015 **2014**

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	8.2	4	1	0
February	8.2	4.75	1	0
March	8.2	4.044444444	1	0
April	8.2	3.4	1	0
May	8.2	5.4125	1	0
June	8.2	4.155555556	1	0
July	8.2	3.79	1	0
August	8.2	4.8875	1	0
September	8.2	4.724	1	0
October	8.2	6.17375	1	0
November	8.2	8.3625	1	1
December	8.2	5.104	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				1
Total Number of Points				10

10

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

We reviewed the plant's operation a increased wasting to reduce the effluent phos. Sorbex is currently being added to improve effluent removal. Phos

Total Points Generated	10
Score (100 - Total Points Generated)	90
Section Grade	B

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:

6/8/2015

2014

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- ☐ Land applied under your permit
☐ Publicly Distributed Exceptional Quality Biosolids
☒ Hauled to another permitted facility
☐ Landfilled
☐ Incinerated
☐ Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 003 - Municipal sludge

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75		<233												0	0
Cadmium		39	85		<58.1												0	0
Copper		1500	4300		<233												0	0
Lead		300	840		<233												0	0
Mercury		17	57		<.028												0	0
Molybdenum	60		75		<233											0		0
Nickel	336		420		<233											0		0
Selenium	80		100		<233											0		0
Zinc		2800	7500		<233												0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

- 0 (0 Points)
○ 1-2 (10 Points)
○ > 2 (15 Points)

3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)

- Yes
○ No (10 points)
● N/A - Did not exceed limits or no HQ limit applies (0 points)
○ N/A - Did not land apply biosolids until limit was met (0 points)

3.1.3 Number of times any of the metals exceeded the ceiling limits = 0

Exceedence Points

- 0 (0 Points)
○ 1 (10 Points)
○ > 1 (15 Points)

3.1.4 Were biosolids land applied which exceeded the ceiling limit?

- Yes (20 Points)
● No (0 Points)

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:

6/8/2015

2014

3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified? <div></div>	0
6. Biosolids Storage 6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site? ● >= 180 days (0 Points) ○ 150 - 179 days (10 Points) ○ 120 - 149 days (20 Points) ○ 90 - 119 days (30 Points) ○ < 90 days (40 Points) ○ N/A (0 Points) 6.2 If you checked N/A above, explain why. <div></div>	0
7. Issues 7.1 Describe any outstanding biosolids issues with treatment, use or overall management: <div>We have no issues at this time all bio solids are hauled off-site</div>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:

6/8/2015

2014

Staffing and Preventative Maintenance (All Treatment Plants)

<p>1. Plant Staffing</p> <p>1.1 Was your wastewater treatment plant adequately staffed last year?</p> <ul style="list-style-type: none">● Yes○ No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>Could use more help/staff for:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?</p> <ul style="list-style-type: none">● Yes○ No <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
<p>2. Preventative Maintenance</p> <p>2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?</p> <ul style="list-style-type: none">● Yes (Continue with question 2)○ No (40 points) <p>If No, please explain, then go to question 3:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?</p> <ul style="list-style-type: none">● Yes○ No (10 points) <p>2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?</p> <ul style="list-style-type: none">● Yes<ul style="list-style-type: none">● Paper file system○ Computer system○ Both paper and computer system○ No (10 points)	0
<p>3. O&M Manual</p> <p>3.1 Does your plant have a detailed O&M Manual that can be used as a reference when needed?</p> <ul style="list-style-type: none">● Yes○ No	
<p>4. Overall Maintenance /Repairs</p> <p>4.1 Rate the overall maintenance of your wastewater plant.</p> <ul style="list-style-type: none">○ Excellent● Very good○ Good○ Fair○ Poor <p>Describe your rating:</p>	

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:

6/8/2015

2014

WE depend on preventive maintenance and contracted services since the plant does not have full time staff.
There is always room for improvement.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:
6/8/2015 **2014**

Operator Certification and Education

<p>1. Operator-In-Charge</p> <p>1.1 Did you have a designated operator-in-charge during the report year?</p> <p>● Yes (0 points)</p> <p>○ No (20 points)</p> <p>Name: GARY W HANSON</p> <p>Certification No: 01590</p>	0
<p>2. Certification Requirements</p> <p>2.1 In accordance with Chapter NR 114.08 and 114.09, Wisconsin Administrative Code, what grade and subclass(es) were required for the operator-in-charge to operate the wastewater treatment plant and what grade and subclass(es) were held by the operator-in-charge?</p> <p>Required:</p> <div style="border: 1px solid black; padding: 5px; margin: 5px 0;">2 - CJ; C - ACTIVATED SLUDGE; J - LABORATORY</div> <p>Held:</p> <div style="border: 1px solid black; padding: 5px; margin: 5px 0;">4 - ABCDEFGHIJ; 4 - A=PRIMARY SETTLING GRADE 4; B=TRICKLING FILTER/RBC GRADE 4; C=ACTIVATED SLUDGE GRADE 4; D=PONDS/AERATED LAGOONS GRADE 4; E=DISINFECTION GRADE 4; F=ANAEROBIC DIGESTION GRADE 4; G=MECHANICAL SLUDGE GRADE 4; H=FILTRATION GRADE 4; I=PHOSPHORUS REMOVAL GRADE 4; J=LABORATORY GRADE 4</div> <p>2.2 Was the operator-in-charge certified at the appropriate level to operate this plant?</p> <p>● Yes (0 points)</p> <p>○ No (20 points)</p>	0
<p>3. Succession Planning</p> <p>3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?</p> <p><input type="checkbox"/> One or more additional certified operators on staff</p> <p><input checked="" type="checkbox"/> An arrangement with another certified operator</p> <p><input type="checkbox"/> An arrangement with another community with a certified operator</p> <p><input type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year</p> <p><input type="checkbox"/> A consultant to serve as your certified operator</p> <p><input type="checkbox"/> None of the above (20 points)</p> <p>If "None of the above" is selected, please explain:</p> <div style="border: 1px solid black; height: 20px; margin-top: 5px;"></div>	0
<p>4. Continuing Education Credits</p> <p>4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates?</p> <p>Grades T, 1, and 2:</p> <p>○ Averaging 6 or more CECs per year.</p> <p>○ Averaging less than 6 CECs per year.</p> <p>Grades 3 and 4:</p> <p>○ Averaging 8 or more CECs per year.</p> <p>○ Averaging less than 8 CECs per year.</p>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:

6/8/2015

2014

Financial Management

<p>1. Provider of Financial Information</p> <p>Name: <input style="width: 150px;" type="text" value="Micheal McKinney"/></p> <p>Telephone: <input style="width: 150px;" type="text" value="2628782123"/> (XXX) XXX-XXXX</p> <p>E-Mail Address (optional): <input style="width: 150px;" type="text"/></p>																			
<p>2. Treatment Works Operating Revenues</p> <p>2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?</p> <ul style="list-style-type: none"> ● Yes (0 points) ○ No (40 points) <p>If No, please explain:</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div> <p>2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?</p> <p>Year: <input style="width: 80px;" type="text" value="2014"/></p> <ul style="list-style-type: none"> ● 0-2 years ago (0 points) ○ 3 or more years ago (20 points) ○ N/A (private facility) <p>2.3 Did you have a special account (e.g., CWFP required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?</p> <ul style="list-style-type: none"> ● Yes (0 points) ○ No (40 points) 	0																		
REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]																			
<p>3. Equipment Replacement Funds</p> <p>3.1 When was the Equipment Replacement Fund last reviewed and/or revised?</p> <p>Year: <input style="width: 80px;" type="text"/></p> <ul style="list-style-type: none"> ○ 1-2 years ago (0 points) ○ 3 or more years ago (20 points) ● N/A <p>If N/A, please explain:</p> <div style="border: 1px solid black; padding: 5px; min-height: 20px;"> We have no debt. We continue to build our reserves. </div> <p>3.2 Equipment Replacement Fund Activity</p> <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 60%;">3.2.1 Ending Balance Reported on Last Year's CMAR</td> <td style="width: 5%; text-align: right;">\$</td> <td style="width: 35%; text-align: right;"><input style="width: 100%;" type="text" value="11,681.00"/></td> </tr> <tr> <td>3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="0.00"/></td> </tr> <tr> <td>3.2.3 Adjusted January 1st Beginning Balance</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="11,681.00"/></td> </tr> <tr> <td>3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)</td> <td style="text-align: right;">+</td> <td style="text-align: right;">\$ <input style="width: 100%;" type="text" value="3,258.00"/></td> </tr> <tr> <td>3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*)</td> <td style="text-align: right;">-</td> <td style="text-align: right;">\$ <input style="width: 100%;" type="text" value="0.00"/></td> </tr> <tr> <td>3.2.6 Ending Balance as of December 31st for CMAR Reporting Year</td> <td style="text-align: right;">\$</td> <td style="text-align: right;"><input style="width: 100%;" type="text" value="14,939.00"/></td> </tr> </table>	3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 100%;" type="text" value="11,681.00"/>	3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$	<input style="width: 100%;" type="text" value="0.00"/>	3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 100%;" type="text" value="11,681.00"/>	3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	\$ <input style="width: 100%;" type="text" value="3,258.00"/>	3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*)	-	\$ <input style="width: 100%;" type="text" value="0.00"/>	3.2.6 Ending Balance as of December 31st for CMAR Reporting Year	\$	<input style="width: 100%;" type="text" value="14,939.00"/>	
3.2.1 Ending Balance Reported on Last Year's CMAR	\$	<input style="width: 100%;" type="text" value="11,681.00"/>																	
3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)	\$	<input style="width: 100%;" type="text" value="0.00"/>																	
3.2.3 Adjusted January 1st Beginning Balance	\$	<input style="width: 100%;" type="text" value="11,681.00"/>																	
3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)	+	\$ <input style="width: 100%;" type="text" value="3,258.00"/>																	
3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*)	-	\$ <input style="width: 100%;" type="text" value="0.00"/>																	
3.2.6 Ending Balance as of December 31st for CMAR Reporting Year	\$	<input style="width: 100%;" type="text" value="14,939.00"/>																	

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:

6/8/2015

2014

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

no equipment purchases for 2014

3.3 What amount should be in your Replacement Fund? \$ 14,939.00

Please note: If you had a CWFP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the HELP link under Info in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

● Yes

○ No

If No, please explain.

We are continuously adding and withdrawing funds from the replacement fund

0

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

● Yes - If Yes, please provide major project information, if not already listed below.

○ No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	Plant upgrade due to new permit requirements	5000000	2019

5. Financial Management General Comments

We are continuously adding and withdrawing funds from the replacement fund and reviewing the financial status of the Utility

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:

6/8/2015

2014

Sanitary Sewer Collection Systems

1. CMOM Program

1.1 Do you have a Capacity, Management, Operation & Maintenance (CMOM) requirement in your WPDES permit?

☐ Yes

☒ No

1.2 Did you have a documented (written records/files, computer files, video tapes, etc.) sanitary sewer collection system operation & maintenance (O&M) or CMOM program last calendar year?

☒ Yes (Continue with question 1)

☐ No (30 points) (Go to question 2)

1.3 Check the elements listed below that are included in your O&M or CMOM program.

☒ Goals

Describe the specific goals you have for your collection system:

reduce I&I as much as possible within an approved budget. Operate a collection system without any backups.

☐ Organization

Do you have the following written organizational elements (check only those that apply)?

☒ Ownership and governing body description

☐ Organizational chart

☐ Personnel and position descriptions

☐ Internal communication procedures

☐ Public information and education program

☐ Legal Authority

Do you have the legal authority for the following (check only those that apply)?

☒ Sewer use ordinance Last Revised Date (MM/DD/YYYY)

☒ Pretreatment/industrial control Programs

☒ Fat, oil and grease control

☒ Illicit discharges (commercial, industrial)

☒ Private property clear water (sump pumps, roof or foundation drains, etc.)

☐ Private lateral inspections/repairs

☐ Service and management agreements

☐ Maintenance Activities (provide details in question 2)

☐ Design and Performance Provisions

How do you ensure that your sewer system is designed and constructed properly?

☒ State plumbing code

☒ DNR NR 110 standards

☒ Local municipal code requirements

☒ Construction, inspection, and testing

☐ Others:

☐ Overflow Emergency Response Plan:

Does your emergency response capability include (check only those that apply)?

☒ Alarm system and routine testing

☒ Emergency equipment

☒ Emergency procedures

☒ Communications/notifications (DNR, internal, public, media, etc.)

☐ Capacity Assurance:

How well do you know your sewer system? Do you have the following?

☒ Current and up-to-date sewer map

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:

6/8/2015

2014

- ☒ Sewer system plans and specifications
- ☒ Manhole location map
- ☒ Lift station pump and wet well capacity information
- ☒ Lift station O&M manuals

Within your sewer system have you identified the following?

- ☐ Areas with flat sewers
- ☐ Areas with surcharging
- ☒ Areas with bottlenecks or constrictions
- ☐ Areas with chronic basement backups or SSOs
- ☐ Areas with excess debris, solids, or grease accumulation
- ☐ Areas with heavy root growth
- ☐ Areas with excessive infiltration/inflow (I/I)
- ☐ Sewers with severe defects that affect flow capacity
- ☒ Adequacy of capacity for new connections
- ☐ Lift station capacity and/or pumping problems
- ☐ Annual Self-Auditing of your O&M/CMOM Program to ensure above components are being implemented, evaluated, and re-prioritized as needed
- ☐ Special Studies Last Year (check only those that apply):
 - ☒ Infiltration/Inflow (I/I) Analysis
 - ☐ Sewer System Evaluation Survey (SSES)
 - ☐ Sewer Evaluation and Capacity Management Plan (SECAP)
 - ☐ Lift Station Evaluation Report
 - ☒ Others:

Annual sampling and testing of all of our industrial and commercial users for BOD, SS, Ammonia, Phos., Zinc, and Chlorides

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input type="text" value="33"/>	% of system/year
Root removal	<input type="text" value="00"/>	% of system/year
Flow monitoring	<input type="text" value="1"/>	% of system/year
Smoke testing	<input type="text" value="1"/>	% of system/year
Sewer line televising	<input type="text" value="33"/>	% of system/year
Manhole inspections	<input type="text" value="0"/>	% of system/year
Lift station O&M	<input type="text" value="104"/>	# per L.S./year
Manhole rehabilitation	<input type="text" value="15"/>	% of manholes rehabbed
Mainline rehabilitation	<input type="text" value="0"/>	% of sewer lines rehabbed
Private sewer inspections	<input type="text" value="0"/>	% of system/year
Private sewer I/I removal	<input type="text" value="0"/>	% of private services

Please include additional comments about your sanitary sewer collection system below:

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:
6/8/2015 **2014**

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

32.58	Total actual amount of precipitation last year in inches
33.71	Annual average precipitation (for your location)
7	Miles of sanitary sewer
3	Number of lift stations
0	Number of lift station failures
0	Number of sewer pipe failures
0	Number of basement backup occurrences
0	Number of complaints
.07	Average daily flow in MGD (if available)
	Peak monthly flow in MGD (if available)
	Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

	Lift station failures (failures/year)
	Sewer pipe failures (pipe failures/sewer mile/yr)
	Sanitary sewer overflows (number/sewer mile/yr)
	Basement backups (number/sewer mile)
	Complaints (number/sewer mile)
	Peaking factor ratio (Peak Monthly:Annual Daily Avg)
	Peaking factor ratio (Peak Hourly:Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OFERFLOWS REPORTED **				
	Date	Location	Cause	Estimated Volume (MG)
None reported				

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

☐ Yes

☒ No

If Yes, please describe:

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

☐ Yes

☒ No

If Yes, please describe:

5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:

none observed

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:
6/8/2015 **2014**

5.4 What is being done to address infiltration/inflow in your collection system?

Continue to TV collect system yearly and make repairs to all leaks as soon as they are found.
rebuild 10 manholes per year.

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:

6/8/2015

2014

Grading Summary

WPDES No: 0029831

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	A	4	5	20
Phosphorus	B	3	3	9
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			37	145
GRADE POINT AVERAGE (GPA) = 3.92				

Notes:

A = Voluntary Range (Response Optional)

B = Voluntary Range (Response Optional)

C = Recommendation Range (Response Required)

D = Action Range (Response Required)

F = Action Range (Response Required)

Compliance Maintenance Annual Report

Yorkville Sewer Utility District No 1

Last Updated: Reporting For:

6/8/2015

2014

Resolution or Owner's Statement

Name of Governing Body or Owner:	Yorkville Sewer Utility District No 1
Date of Resolution or Action Taken:	06/16/2016
Resolution Number:	

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F. Regardless of grade, required for Collection Systems if SSOs were reported):

Effluent Quality: BOD: Grade = A

Discussed and approved

Effluent Quality: TSS: Grade = A

Discussed and approved

Effluent Quality: Ammonia: Grade = A

Discussed and approved

Effluent Quality: Phosphorus: Grade = B

Discussed and approved

Biosolids Quality and Management: Grade = A

Discussed and approved

Staffing: Grade = A

Discussed and approved

Operator Certification: Grade = A

Discussed and approved

Financial Management: Grade = A

Discussed and approved

Collection Systems: Grade = A

Discussed and approved

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS (Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 3.92

Discussed and approved