



Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
PARKING LOT	Illuminance	Fc	1.58	4.7	0.1	15.80	47.00
PROPERTY LINE	Illuminance	Fc	0.49	4.8	0.0	N.A.	N.A.

Luminaire Schedule										
Symbol	Qty	Label	Tag	Description	Arrangement	Lum. Lumens	Lum. Watts	LLF		
□	10	PA	McGRAW	GALN-SA8C-727-U-T4FT-HSS	Single	34188	429	0.880		

- Standard Reflectance of 80/50/20 unless noted otherwise
- Not a Construction Document, for Design purposes only
- Standard indoor calc points @ 30' A.F.F. unless noted otherwise
- Standard outdoor calc points @ Grade unless noted otherwise
- Egress calc points @ 0' A.F.F.
- Mlazgar Associates assumes no responsibility for installed light levels due to field conditions, etc.

#	Date	Comments
Revisions		

RLMA Project #: _____
 Drawn By: KWH
 Date: 4/5/2023
 Scale: 25' = 1'-0"

WILLKOMM LOT LIGHT - QUICK MOUNT OPTION
 EXTERIOR SITE LIGHTING
 RACINE, WI